Manuale d'Uso

memo NFC

Digital time switch: User Manual









Index

Technical features Safety warnings Dimensions Wiring diagrams Display and keyboard description Initial operation Start page (or main) Menu description Settings menu Language setting menu Date setting menu Date setting menu Daylight saving time (DST)/winter time (CET) change setting menu Program genu Random switchings setting menu Protection PIN setting menu Program menu: new Program menu: new Program menu: new Program menu: new weakly timed Program menu: new yearly timed Program menu: new holiday timed	page page page page page page page page	3 4 4 5 6 7 8 11 12 13 14 15 16 18 19 20 25 26 27 8 30 32 34
Program menu: modify		34
Program menu: copy Program menu: delete	page page	36 37

NFC menu	page	38
Hour couter menu	page	40
Reset menu	page	42
Firmware menu	page	44
Error signals	page	45
Battery management	page	46
Reference standards	page	46

USER MANUAL

The digital time switches of memo series are electronic devices for the management of the electrical utilities over time. They allow the time programming (periodicity: daily, weekly or yearly) and have a NFC interface that allows it to be coupled with mobile devices (smartphone or tablet).

Thanks to the free app that can be downloaded from Google Play store, it is possible to program and make settings directly on your smartphone and then transfer all the data to the time switch.

The reverse procedure is also possible, i.e. to copy the programming of a time switch on your mobile device.

The backup battery allows you to keep the settings even in case of black-out and can be replaced through the cover on the back of the time switch.

The time switches of Memo series are devices that perform actions of 1B type , intended to operate in environments with III overvoltage category and pollution degree 2 in accordance with EN 60730-1 standard.

Code	Model	Description
VE339800	memo DW	Daily/weekly time switch 1 channel with NFC interface
VE341400	memo DW2	Daily/weekly time switch 2 channels with NFC interface
VE340600	memo Y	Daily/weekly or yearly time switch 1 channel with NFC interface
VE342200	memo Y2	Daily/weekly or yearly time switch 2 channels with NFC interface

TECHNICAL FEATURES

- Power supply: 230 Vac (-15% ÷ +10%) 50/60 Hz
- Power consumption:
 - memo DW, memo Y: 1W (3.5 VA)
 - memo DW2, memo Y2: 1.5W (5.5 VA)
- Lithium backup battery: 3V, CR2032 type (replaceable)
- Output:
 - memo DW, memo Y: 1 monostable change-over relay with


maximum switchable load

- of 16(10)A / 250V
- memo DW2, memo Y2: 2 monostable change-over relays with maximum switchable load of 16(10)A / 250V
- Display LCD with backlighting (active with AC power supply)
- NFC communication interface
- Storable programs:
 - memo DW, memo Y: 120 events
 - memo DW2, memo Y2: 120 events (divisible on 2 channels)
- Actions type: 1B
- Operating temperature: -20 ÷ +50°C
- Operating humidity: 20 ÷ 90% non condensing
- Storage temperature: -25°C ÷ +70°C
- Container: 2 DIN modules

- Protection degree: IP20
- Insulation: reinforced between accessible parts (front) and all the other terminals


SAFETY WARNINGS

- During product installation and operation it is necessary to observe the following instructions:
- The instrument must be installed by a qualified person, strictly in observance of the connection diagrams shown in this manual.
- 2) After installation inaccessibility to the terminals without using dedicated tools must be guaranteed.
- 3) Before accessing the connection terminals, make sure that the leads are not live.
- Do not connect or feed the instrument if any part of it is damaged.
- 5) The product must be installed and activated in compliance with current electric systems standards.
- 6) Do not use the product for anything other than the indicated purpose.
- 7) In the electrical system upstream of the device must be installed a protection device against the overcurrents
- 8) The product can be used in environments with Measurement Category III and Pollution degree 2, according to the Standard EN 60730-1.




WIRING DIAGRAMS






Memo DW2, Memo Y2




DISPLAY AND KEYBOARD DESCRIPTION



① General indications

(3

- ② Time indication
- ③ Channel 1/channel 2 status indication
 - □_ / □ FF channel status
 - blocked switchings
 - ⑦ active random switchings
 - A active holiday program
 - L active pulse program
 - C active manual program
- ④ Day of the week (DAY) indication



(5) Turn on the display

(5


- Access the menu ESC (one level back)
- (6) Key "C1": decrease datum/previous menu/ switching channel 1/ lock channel 1
 - Key "C2": increase datum/next menu/ switching channel 2 / lock channel 2
- ⑦ Confirm selection
- 8 Hardware reset
- Key **"Ok" + "C1"** (3 sec): random switching channel 1 Key **"Ok" + "C2"** (3 sec): random switching channel 2

INITIAL OPERATION

- Once out of the package, memo is off: press the key and wait a moment before activating the display
- The set language is Italian. To change it, press the key I for at least 3 seconds. Choose among: Italian, English, Spanish, French or German and confirm with II
- Make connections following the diagrams on page 5 of this manual
- · Power memo: the backlighting turns on permanently
- The presence of the backup battery allows the memo to have updated date and time.
 To make the other settings follow the following steps:

Date	 format: DD/MM/YY 1st day of the week: Monday
Daylight Saving time (DST) change: active	 start of daylight saving time (DST): last Sunday of March at 02:00 o'clock end of daylight saving time (DST): last Sunday of October at 03:00 o'clock
Random switchings:	- minimum: 1 minute - maximum: 5 minutes
Keyboard lock with PIN:	disabled ()
NFC interface	active

START PAGE (or main)





NOTE: the NFC interface is active only when the memo displays the initial (main) page. The action range of the NFC interface is deliberately limited: in order for the memo and the smartphone to communicate, it is necessary to place the latter on the memo display.

Information messages

- day of the week
- product identification code and serial number
- battery status (only if discharged)
- -NO 5UPPLY*
- · Press the key
- to access the menu of memo
- and c to change channel 1 and channel 2 status (only for memo DW2, memo Y2)

* Only if memo is not powered by mains. In this condition the backlighting is not active and the relay is in off status. Access the store of your device, install and start the free app Memo - Vemer.

(2)







English

- ① At the start the app displays the list of the associated memo devices (both Bluetooth and NFC). To associate a new memo NFC, press the symbol "+" in the upper right corner.
- 2 In the "Choose connection type" screen, select NFC.
- ③ Place the smartphone on the display of the memo to be associated.

Note: each device is identified by the product code (for example VE339800) and by the serial number (for example 00000020). These informations can be viewed from the main page of the memo.


Warning: make sure visible that the display shows the main page (initial). Otherwise the NFC interface is not active and the device is not visible.

Note: from this screen you can create a virtual memo. With a virtual memo you can create programs even if you do not have a memo available. The programming and settings of the virtual memo can be saved in the app and then transferred to the memo.

③ The app shows the detected memo: do a tap on the memo to complete the association. Once the procedure is complete, the memo is added to the list of associated devices. Select the memo on which to act from the list of associated devices.

- ^⑤ The app displays the initial page of the selected memo. From this page you can:
 - a. Create new programs that will then be copied to the memo
 - b. View the parameters and associate an alias (name that identifies the time switch, such as "memo DW Belluno") to the memo

MENU DESCRIPTION



SETTINGS MENU


"Settings" menu allows you to view and eventually to modify the general operation settings of memo, such as:

(1) language


2 date

③ time


- ④ automatic daylight saving time (DST) change
- (5) position (astronomical coordinates)
- ⁽⁶⁾ interval duration between two random switchings
- ⑦ keys protection by PIN



Language setting menu



Date setting menu




OK

C1 C2

- ① Possible date formats: day-month-year (러구 MM / 님님), year-month-day (님님 / MM / 러리), month-day-year (MM/러러/님님).
- © Choose, by convention, the first day of the week. In Italy, for example, the first day of the week is Monday, in the UK it's Sunday.
- ③ Enter the date: day, month, year.

Time setting menu




Set the time: hours, minutes.

Daylight saving time (DST)/winter time (CET) change setting menu


Daylight saving time (DST)/winter time(CET) change and vice versa can occur in an automatic way. In this case, memo:

- increases by an hour in the passage from winter time (CET) to daylight saving time (DST)
- decreases by an hour in the passage from daylight saving time (DST) to winter time (CET)

For every change it's necessary to specify:




In Italy, for example, daylight saving time (DST) begins occurs the last (LRSE) Sunday (7) of March (33) at 2200 o'clock, and ends the last (LRSE) Sunday (7) of October (30) at 3300 o'clock.



- ① Choose to activate (AULO ON) or to disable (AULO OFF) the automatic time change.
- ② Set date and time of the winter time (CET) daylight saving time (DST) change.

③ Set date and time of the daylight saving time (DST) winter time (CET) change.

Random switchings setting menu




The "random switching O" function (activated with the combination described on page 6) allows the channel on which it's active to automatically switch and at random time intervals.

In this menu it's possible to define the minimum and maximum duration of the time interval between two random switchings. Default minimum duration is 1 minute, maximum duration is 5 minutes.

Parameters modification

① Set the minimum duration. It's possible to set values between 1 minute and the *maximum duration*. ② Set the maximum duration. It's possible to set values between the *minimum duration* and 23:59 hours. Note: setting the minimum duration equal to the maximum, the switchings will occur at fixed time intervals.

Protection PIN setting menu



The protection code (PIN) is used to lock the keyboard and prevent changes by unauthorized persons. With active PIN protection, pressing any key, it's necessary to enter the PIN: if PIN is correct the keyboard unlocks; after 3 minutes without pressing a key, the keyboard will lock automatically.

To activate PIN protection:

- set a value between 000 and 999

To disable PIN protection:


- set "---" (located before 000 or after 999)


Note: If you have forgotten your PIN code to unlock memo it's necessary to carry out a hardware reset (see page 42).

PROGRAM MENU

The menu "program" allows you to:

- (1) create a new program
- 2 check created programs
- ③ change or delete a created program
- (4) copy all created programs of channel 1 on channel 2 and vice
- versa (only for memo DW2, memo Y2)
- (5) delete all programs of a channel





Programs types

- ON/OFF program: is composed of a switching of the ON relay and of a subsequent switching of the OFF relay. It can have a daily period (everyday with the same modes), weekly (every week with the same modes), yearly (all the years with the same modes. Available only on memo Y and memo Y2).
- PULSE ON program: is an ON relay switching for a maximum duration of 59 seconds. It can have a daily period (everyday with the same modes), weekly (every week with the same modes), yearly (all the years with the same modes. Available only on memo Y and memo Y2).
- PULSE OFF program: is a relay switching OFF for a maximum duration of 59 seconds. It can have daily period (everyday with the same modes), weekly (every week with the same modes), yearly (all the years with the same modes. Available only on memo Y and memo Y2).
- HOLIDAY program: is a period of time defined by a start time and an end time within which all programmed switchings (of that channel) are disabled. The relay is in OFF position (OFF holiday) or in ON position (ON holiday).
- ▲ Important: on the same channel can't coexist ON pulses and OFF pulses (if an ON pulse is already present, it's not possible to save a holiday OFF and vice versa).
- ▲ Important: on the same channel can't coexist holiday ON programs and holiday OFF programs (if a holiday ON program is already present, it's not possible to save a holiday OFF program and vice versa).

Programs priority


The priority programs defines how memo manages the case in which programs with different period are running at the same time (1 indicates higher priority).

Program	Date* (specific year)	Yearly (specific month, every year)	Monthly (every month, every year)	Weekly	Daily
Holiday			1		
Pulse	2	3	4	5	6
On/Off	7	8	9	10	11

* Date: select day, month, year (program carried "only once in the life of the product"). If the month is not specified, the program is carried out all days xx of all months of the specified year.

Priority list on/off


In case in which, on the same channel, on/off programs are provided with different period (daily, weekly or yearly) to carry out in the same day, only the program with the highest priority is executed.




From this example it's possible to see that the daily event on Monday is not carried out because in the same day it is provided the beginning of the week program (even if the daily program of Monday begins and ends before the beginning of the weekly program). Instead, the daily program of Sunday is carried out because it's the only one running for that day.


Holiday program

The holiday program just begins and ends exactly at the specified times.






① Choose the channel to program (only for memo DW2 and memo Y2)



Program menu: new daily timed

Program parameters


- on/off: on time and off time
- on pulse: time and pulse duration (max 59 seconds)
- off pulse: time and pulse duration (max 59 seconds)



- on pulse: day (or days)* and pulse time, pulse duration (max 59 seconds)
- off pulse: day (or days)* and pulse time, pulse duration (max 59 seconds)

* See "Days selection" on page 21

- 27 -User manual memo NFC



- off pulse: day (or days) * and pulse time, pulse duration (max 59 seconds)

* see "How to choose the day (or days) in a yearly program" on p. 29

- 28 -

User manual memo NFC




1 to set the program:


in the first, second, third, fourth or last week of the month in / the day/s (Monday, ...) of the week just specified the specified month (MM for all months) the given year (실명 or all years)

Nota: in this case, the yearly program must begin and end in the same day. Otherwise $ERROR \ O \ O$ is signaled.

- (2) to set the program on the last day:
- ---- / MM / 99 of all months of all years
- ---- / V V / 99 of the specified VV month of all years
- ---- / MM / ZZ of all months of the specified ZZ year
- \cdots / V V / Z Z of the specified VV month of the specified ZZ year



Program menu: new holiday time



0 HOLIDAY OFF: the relay is OFF from the beginning to the end of holiday program. 0 HOLIDAY ON: the relay is ON from the beginning to the end of holiday program.

Program parameters

- beginning of the program
- end of the program




1 to set the program:


in the first, second, third, fourth or last week of the month in / the day/s (Monday, ...) of the week just specified the specified month (MM for all months) the given year (실명 or all years)

Note: in this case, the holiday program must begin and end in the same day. Otherwise ERRIR \Box II is signaled.

- 2 to set the program on the last day:
- ---- / MM / 99 of all months of all years
- ---- / V V / 99 of the specified VV month of all years
- ---- / MM / ZZ of all months of the specified ZZ year
- \cdots / V V / Z Z of the specified VV month of the specified ZZ year



Program menu: check



How to check a program


(1) choose the channel (only for memo DW2, memo Y2)

2 choose the period: daily, weekly, yearly, holiday


③ choose the type: on/off, on pulse, off pulse

Note: a program requires more screens to be displayed:

- press the key or to move from the first to the second part of the same program
- press the keys C1 and C2 to switch from one program to another



Program menu: modify



How to modify or to delete a program

① choose the channel (only for memo DW2, memo Y2).


2 choose the period: daily, weekly, yearly, holiday


③ choose the type: on/off, on pulse, off pulse

Note: a program requires more screens to be displayed:

- press the key **OK** to move from the first to the second part of the same program
- press the keys Cl and C2 key to switch from one program to another


To modify: press for a long time (at least 3 seconds) the key ok To delete: press for a long time and simultaneously the keys ok and -





"Copy" menu allows copying the programs of a channel (origin channel) on the other channel (channels destination). Note: the programs previously stored on the channel destination will be deleted.





"Delete" menu is used to delete all stored programs on the specified channel. Note: to delete one single program to see "modify" mode (see page 34).

NFC MENU

The NFC menu allows you to enable or disable the NFC interface.


To enable the NFC interface:

① set NFC ON

Warning: to make the NFC interface active, the memo must displays the main page (see page 8). The NFC interface is therefore not active when browsing through the memo NFC menus. To guarantee a stable communication, lay the smartphone on memo's display.

In this way no communication can take place between your device and memo.

The memo works with the settings and programs already set; any changes or creation of new programs must be made by acting directly on the keyboard of memo.




HOUR COUNTER MENU

"Hour counter" menu allows you to display the hours of use (relay on) of connected loads. The maximum value of the counter is 99999 hours (about 11 years); reached the maximum limit, the counter resets automatically.

To reset a counter:

- **1.** select the desired channel (only for memo DW2 and memo Y2)
- 2. press the key ok for 3 seconds until the display shows "HOUR ENE DELEEE O"
- 3. confirm by pressing ok (press 🖃 to exit without zeroing)

Note: it's possible to reset all counters contemporary from the "Reset" menu (see page 42).



RESET MENU

"Reset" menu allows you to restore the initial state of the device.

Available resets:


① Settings reset: deletes all the carried out settings (except the language and the PIN)

- ② Time programs reset: deletes all saved time programs
- ③ Holiday programs reset: deletes all saved holiday programs
- ④ Counter reset: resets the counters of all channels
- ^⑤ Reset all: carries out all the above described resets and deletes the language and PIN protection


There is also another reset, of hardware type, which allows you to reset the device in case it responds to the pressing of the keys so unexpectedly, without losing the carried out settings/programs (only the date and the time are lost).

To carry out a hardware reset:

1. press the key "R" with a sharp object




The hardware reset is also useful when you forget PIN protection. Reset, in fact, unlocks the keyboard for 3 minutes, the necessary time to access the appropriate menu and check/disable PIN.



FIRMWARE MENU

This menu shows the firmware installed in the device, where: 022 is the revision index 05 is the month 20 is the day



ERROR SIGNALS

When setting up programs, in case of a discrepancy, the following error messages can occur:

- ERROR DD I on and off events with different frequency (each on event must have an off event)
- ERROR CC2 on and off concomitant events of the same program
- ERROR DDB Two or more consecutive on events of the same program / Two or more consecutive off events of the same program
- ERROR COH Invalid date
- ERROR COS Insufficient memory
- ERROR DD5 Attempt to set an on pulse on a channel where is already stored an off pulse (see page 25)
- ERROR DD1 Attempt to set an off pulse on a channel where is already stored an on impulse (see page 25)
- ERROR COB Attempt to set an on holiday program on a channel where is already stored an off holiday program (see page 30)
- ERROR DOS Attempt to set a holiday off program on a channel where a holiday on program is already stored (see page 30)

- ERROR C IC Attempt to set a holiday program of on and off events on different days of the week (see page 31) ERROR C3C Error accessing memory *
- * In this case, carry out a hardware reset (see page 42). If the error persists, contact Vemer technical support (tel.+ 39.0439.879885).

BATTERY MANAGEMENT

When the battery is close to empty, on the first line of the display appears bALEERS. In this case, the battery must be replaced as soon as possible. **Use only batteries of CR2032.** To replace the battery:

- disconnect the mains
- remove the battery slot cover, turning it anti-clockwise
- replace the battery and remount the cover, turning it clockwise
- connect the power supply

Warning: do not use metal objects (such as screwdrivers) to remove the battery because this may cause the power reserve to be canceled, resulting in a loss of date and time.

Warning: in order not to lose date and hour set, it is necessary to ensure that the time for the battery replacement doesn't exceed 60 seconds (in absence of power by means).



Dispose of the used batteries observing the laws in force in relation to the disposal of hazardous waste.

REFERENCE STANDARDS

Compliance with Community Directives: 2014/35/EU (LVD) 2014/30/EU (EMCD) is declared in reference to the harmonized Standards • EN 60730-2-7



Vemer S.p.A. I - 32032 Feltre (BL) • Via Camp Lonc, 16 e-mail: info@vemer.it - web site: www.vemer.it

07-2020